

Peak Load Forecast by Planning Authority

Planning Authority	2020 Load (MW)	Net Annualized 10 yr Growth Rate (%) ⁽¹⁾	Demand Side Programs Included in Load Forecast ⁽²⁾
Duke Energy Carolinas	23,850	1.60%	452
Entergy	28,801	1.30%	in
FPL		1.92%	in
IESO	23,195	-0.09%	4,491
ISO-NE	31,033	0.99%	1,969
JEA	3,399	2.46%	178
MAPP	9,352	1.50%	in
MEAG Power	2,508	1.82%	0
MISO	132,018	0.94%	in
NYISO	35,334	0.78%	2,510
PJM	174,724	1.70%	7,372
PS	2,259	1.58%	23
SCEG		2.20%	no
Southern Company	57,385	2.13%	996
SPP	58,000	1.40%	200
Tennessee Valley Authority	40,588	1.93%	0

(1) - Net Annualized Growth Rate is after any energy efficiency programs

(2) - Includes energy efficiency programs etc in the load forecast

(3) - Includes approximately one third of Energy Efficiency Portfolio Standard instituted in NY, if full programs are implemented, this would be 5,000 MW of reduction